



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6000527
Permit # 01065-2020UPG
Request Rec'd 07/22/2020
Amended Date
Approval Date 7/30/2020 DS
Permit Expires 2/1/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: USAF Air Mobility Command 375th CES/CEV 701 Hangar Road Scott AFB, IL 62225 Contact: Terry Compton (618) 744-9245	(2) <u>FACILITY</u> - name and address where tanks are located: Scott AFB - Building 1575 375th CES/CEV 701 Hangar Road Scott AFB, IL 62225 Contact: Christopher Carlisle (618) 256-2092
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 104, 105, 106, 107) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 104, 105, 106, 107) Piping - Flexible Double Wall OPW Flexworks, (TK # 104, 105, 106, 107) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 104, 105, 106) - Gasoline - Regular, (TK # 107) - Gasoline - Premium*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replaced piping exceeds 20 feet or 50% of the total pipe run.

NOTES: Piping is being replaced in the existing trench and there are existing sump sensors to be re-used. A removal permit must be obtained for the piping removal.


(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Superior Acquisition LLC d/b/a Superior Equipment Company

7525-A Sussex
St. Louis, MO 63143

Contact Person: Matt Gross
Phone: (314) 644-6000
Contractor Registration # IL002394 Exp. 2/26/2021

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File