



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6008081
Permit # 01078-2020UPG
Request Rec'd 07/31/2020
Amended Date
Approval Date 8/3/2020 DS
Permit Expires 2/3/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Kooshtard Property V, LLC 1370 Avenue of the Americas, 21st Floor New York, NY 10019 Contact: Charlene Troyer (630) 800-6065</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Circle K #4700152 1531 West Main Street Salem, IL 62881 Contact: Barbara/Jody Glenn (812) 379-9227</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 15,000, (TK # 6, 7, 8) - 8,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5, 6, 7, 8) Piping - Flexible Double Wall OPW Flexworks from existing tanks to existing dispenser locations, (TK # 5, 6, 7, 8) Piping - Ball Valves, (TK # 5, 6, 7, 8) Piping - Shear Valves, (TK # 5, 6, 7, 8) Piping - Flex Connector Steel, (TK # 5, 6, 7, 8) Piping - Single Wall STP/Tanktop Sump, (TK # 5, 6, 7, 8) Piping - Composite Chase*
- (d) *Product to be stored in each tank: (TK # 5, 6) - Gasoline - Regular, (TK # 7) - Gasoline - Premium, (TK # 8) - Diesel Fuel*
- (e) *Type of leak detection being used:*
- Tank:*
- Piping:*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 5, 6, 7, 8) Spill Contain Device - Double Wall Spill Bucket*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Installing of all new STP sumps, UDC sumps, product piping chase piping, shear valves, flex connectors, ball valves, and island-less islands. Re-install exsiting sumps sensors.

Replaced piping exceeds 20 feet or 50% of the total pipe run.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File