



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

**FOR OFFICE USE ONLY**

Facility # 4036099  
Permit # 00840-2020UPG  
Request Rec'd 06/11/2020  
Amended Date 08/03/2020 DS  
Approval Date 6/15/2020 DS  
Permit Expires 12/15/2020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Mac's Convenience Stores, LLC 550 Warrenville Rd., Suite 400 Lisle, IL 60532</p> <p>Contact: Mike Sawkiewicz (919) 774-6700 Ext. 6978</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Circle K #1251 2302 West Market Bloomington, IL 61701</p> <p>Contact: Steve Elezi (815) 961-1700</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 3) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3) Piping - Flexible Double Wall OPW Flexworks, (TK # 3) Piping - Ball Valves, (TK # 3) Piping - Shear Valves, (TK # 3) Piping - Flex Connector Steel, (TK # 3) Piping - Single Wall Transition Sump*
- (d) Product to be stored in each tank: (TK # 3) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 3) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in new transition sump as well as in the submersible and dispenser sumps if sensors aren't already existing.*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Replaced piping exceeds 20 feet or 50% of the total pipe run.

Amendment Reason: Installation of additional product piping, UDC sumps, and a transition sump.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Contact Person: Jimmy Spiros

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
St. Louis, MO 63139

Phone: (314) 772-4501  
Contractor Registration # IL1502 Exp. 3/26/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File