



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6009507
Permit # 01120-2020UPG
Request Rec'd 08/10/2020
Amended Date
Approval Date 8/10/2020 DS
Permit Expires 2/10/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Orchard Shell Service, LLC 1900 Vandalia Eagan, IL 62234 Contact: Steve Seuss (618) 345-1827	(2) <u>FACILITY</u> - name and address where tanks are located: Orchard Shell Service, LLC 1900 North Vandalia Collinsville, IL 62234 Contact: Steve Seuss (618) 345-1827
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 6, 7) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 6, 7) Piping - Ball Valves, (TK # 6, 7) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 6) - Gasoline - Regular, (TK # 7) - Gasoline - Premium*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 6, 7) Spill Contain Device - Double Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 6, 7) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Tanks 6 & 7 will have new STP sumps, spill buckets, and OFV installed. Following installation, the sumps will be hydrotested and the lines pressure tested.

NOTE: Site does not have ball floats

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Superior Acquisition LLC d/b/a Superior Equipment Company

Contact Person: Matt Gross
Phone: (314) 644-6000

7525-A Sussex
St. Louis, MO 63143

Contractor Registration # IL002394 Exp. 2/26/2021

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File