



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 5041700  
Permit # 01126-2020UPG  
Request Rec'd 08/10/2020  
Amended Date  
Approval Date 8/10/2020 DS  
Permit Expires 2/11/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Hy-Vee, Inc. 5820 Westown Parkway West Des Moines, IA 50266  Contact: John Brummit (515) 267-2800	<b>(2) FACILITY</b> - name and address where tanks are located:  Hy-Vee Gas 310 N. 36th Street Quincy, IL 62301  Contact: Tony Urbanc 2172280618
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 20,000, (TK # 3) - 14,000, (TK # 4) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2, 3, 4) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 1) - Gasoline - Non Ethanol, (TK # 2, 3) - Gasoline - Regular, (TK # 4) - Gasoline - Premium*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2, 3, 4) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 1, 2, 3, 4) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Remove existing concrete over tanks. Excavate to tank top. remove existing spill buckets and risers. Install new steel risers and OPW 2200 series 5 gallon spill buckets wrap steel risers with corrosion tape. Remove existing tank sumps. Install new Bravo single wall fiberglass sumps. Re install existing sub pumps. Install new entry boots. Re attach existing APT flex pipe to existing sub pumps. Fill with water above penetrations and test. Install new EBW Defender series overfill valves. After inspection, backfill with clean stone and set all new manholes. Pour concrete and complete project.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Contact Person: Steve Disselhorst

All Line Equipment, Inc.  
5519 Skyline Drive, PO Box 5257  
Quincy, IL 62305

Phone: (217) 224-9725  
Contractor Registration # IL002319 Exp. 12/23/2021

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File