



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

**FOR OFFICE USE ONLY**

Facility # 2015989  
Permit # 01127-2020UPG  
Request Rec'd 08/10/2020  
Amended Date 08/11/2020 DS  
Approval Date 8/10/2020 DS  
Permit Expires 2/11/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Brothers Real Estate, LLC 54 E. Grand Ave. Fox Lake, IL 60020</p> <p>Contact:</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Fox Lake Shell 54 E. Grand Ave. Fox Lake, IL 60020</p> <p>Contact: Saji Thomas (847) 922-3335</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3, 4) - 6,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3, 4) Piping - Other Steel Riser*
- (d) *Product to be stored in each tank: (TK # 1, 2, 4) - Gasoline - Regular, (TK # 3) - Gasoline - Premium*
- (e) *Type of leak detection being used:*

*Tank: (TK # 1, 2, 3, 4) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD*

*Piping: (TK # 1, 2, 3, 4) Leak Detect - Piping - Piping Sump Sensors Not Regulated Not Installed*

- (f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2, 3, 4) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 1, 2, 3, 4) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Amendment Reason: Site had sensors that were non regulated. We will be removing them. Also the overfill alarm will no longer be used. Overfill drop tubes will be the only method of overfill protection. All tanks.

**NOTE: Inspector Adams verified that the piping at this site is indeed single wall in a chase**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Contact Person: Chris Derro

Cardinal Compliance LLC  
730 Creel Dr  
Wood Dale, IL 601910000

Phone: (708) 452-8620  
Contractor Registration # IL002418 Exp. 3/18/2021

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File