



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6001412
Permit # 01142-2020UPG
Request Rec'd 08/12/2020
Amended Date
Approval Date 8/12/2020 DS
Permit Expires 2/13/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Mark R. Boyer as Beneficiary of the Mark R. Boyer and Donna J. Boyer Revocable Living Trust Dated November 9, 2018 121 E. Vandalia Street Edwardsville, IL 62025 Contact: Mark Boyer (618) 656-5001</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Ron's Shell Service 121 East Vandalia Edwardsville, IL 62025 Contact: Ronald Boyer (618) 656-5001</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 7) - 14,000, (TK # 8) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 7, 8) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L, (TK # 7, 8) Piping - Steel Single Wall Piping, (TK # 7, 8) Piping - Shear Valves, (TK # 7, 8) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 7) - Gasoline - Regular, (TK # 8) - Gasoline - Premium*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


- (5) **SPECIAL CONTINGENCIES** : The premium line failed a .1 gph test and a small leak was discovered under dispenser 1/2. We will install an APT poly dispenser sump and modify the existing singlewall FRP product piping to fix the leak and install the dispenser sump. Install new flex connectors and shear valves. The existing island will be removed and the sump will be set at grade level with 4" pipe bollards.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
4444 Union Blvd.

Contact Person: Terry Smith
Phone: (314) 241-3767

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File