



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2025492  
Permit # 01164-2020ABN  
Request Rec'd 08/11/2020  
Amended Date  
Approval Date 8/19/2020 DS  
Permit Expires 2/19/2021

**Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Kapil Singh, LLC 6347 W. Roosevelt Rd. Berwyn, IL 60402  Contact: Kapil Singh (630) 205-6429</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Kapil Singh, LLC d/b/a Berwyn Fuel Stop 6347 W. Roosevelt Rd. Berwyn, IL 60402  Contact: Kapil Singh (630) 205-6429</p>
---	--

(3) **ABANDONMENT IN PLACE OF TANKS:**

- (a) *Number and size tanks being abandoned: (TK # 3) - 4,000*
- (b) *Product stored in each tank: (TK # 3) - Diesel Fuel*
- (c) *Location of tanks being abandoned: Tank failed lining inspection. The failed diesel tank is located approximately 3 feet from the adjacent 10,000 gallon gasoline tank and damage to the existing gas tank and equipment could occur if diesel tank would be removed from ground*
- (d) *Location of piping being abandoned:*

(4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) **SPECIAL CONTINGENCIES** : NOTE: Permit application does not mention piping being abandoned, therefore it must be removed or abandoned or tied into existing piping under a separate upgrade application

(6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(7) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Armor Shield of Wisconsin  
1875 Highland Court  
Slinger, WI 53086

Contact Person: Clayton Bennett  
Phone: (262) 644-6447  
Contractor Registration # IL1707 Exp. 4/18/2022

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File