



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Extended

FOR OFFICE USE ONLY

Facility # 2012645
Permit # 00593-2020INS
Request Rec'd 04/17/2020
Amended Date
Approval Date 4/20/2020 DS
Permit Expires 4/20/2021

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Northlake BP, Inc. 2900 N. Wolf Rd. Northlake, IL 60164 Contact: Alfred Karalli (773) 430-2123	(2) <u>FACILITY</u> - name and address where tanks are located: Northlake BP, Inc. 2900 N. Wolf Road Northlake, IL 60164 Contact: Sam Moon (847) 447-3237
--	---

(3) INSTALLATION OF TANKS:

- (a) *Number and size of tanks being installed: (TK # 6) - 20,000, (TK # 7) - 3,000*
- (b) *Type of tank(s): (TK # 6, 7) Tank - Fiberglass Double Wall XERXES*
- (c) *Type of piping: (TK # 6) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from tank to dispensers as shown in site plan, (TK # 6, 7) Piping - Ball Valves, (TK # 6, 7) Piping - Shear Valves, (TK # 6, 7) Piping - Flex Connector Steel, (TK # 6, 7) Piping - Single Wall STP/Tanktop Sump, (TK # 7) Piping - Flexible Double Wall OmegaFlex DoubleTrac from tank to dispensers as shown in site plan*
- (d) *Product to be stored in each tank: (TK # 6) - Diesel Fuel, (TK # 7) - Diesel Exhaust Fluid (Non-Regulated)*
- (e) *Type of leak detection being used:*

Tank: (TK # 6, 7) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD, (TK # 6, 7) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring

Piping: (TK # 6) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection, (TK # 6, 7) Leak Detect - Piping - Discriminating Sump Sensor with positive shutdown in submersible and dispenser sumps

NOTE: Sensors must shut down the submersible pump upon detection of a leak

- (f) *Corrosion Protection being used:*

Tank: (TK # 6, 7) Corrosion Prot - Tank - Fiberglass Non-Corrosive

Piping: (TK # 6) Corrosion Prot - Piping - Fiberglass Non-Corrosive, (TK # 7) Corrosion Prot - Piping - Flexible Non-Corrosive

- (g) *Spill containment devices, piping and dispenser containment devices: (TK # 6) Spill Contain Device - Double Wall Spill Bucket, (TK # 7) Spill Contain Device - Single Wall Spill Bucket Horizontal Cabinet*

- (h) *Overfill prevention devices: (TK # 6, 7) Overfill Prev Device - Overfill Drop Tube Valve*

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All

steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.


- (6) **SPECIAL CONTINGENCIES : NOTE: Site plan shows one of the dispensers is 10' from the property line, please verify that it is a full 10' or it will not be allowed under section 175.450 f) 5) as all dispensers must located 10 feet or more from buildings and property lines.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Ron Anderson
Phone: (708) 478-6190
Contractor Registration # IL002275 Exp. 5/21/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File