



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2013238  
Permit # 01168-2020UPG  
Request Rec'd 08/18/2020  
Amended Date  
Approval Date 8/19/2020 DS  
Permit Expires 2/19/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  United Parcel Service 2525 Shermer Road Northbrook, IL 60062  Contact: Eric Kazonovitz (708) 480-6720	<b>(2) FACILITY</b> - name and address where tanks are located:  United Parcel Service 2525 Shermer Road Northbrook, IL 60062  Contact: David Solis (630) 628-2156
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 9) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 9) Piping - Other Steel Riser*
- (d) Product to be stored in each tank: (TK # 9) - Gasoline - Regular*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices: (TK # 9) Spill Contain Device - Double Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 9) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

remove and replace fill riser  
remove and replace drop tube  
remove single wall spill bucket and install new OPW Edge double wall spill bucket

**NOTE: Site does not have existing ball floats**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Contact Person: Robert Stenstrom

Stenstrom Petroleum Services Group  
2422 Center Street  
Rockford, IL 61108

Phone: (815) 398-6250  
Contractor Registration # IL1890 Exp. 4/12/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File