



City of Chicago  
Department of Public Health  
333 South State Street, Room 200  
Chicago, IL 60604  
3127453162

**FOR OFFICE USE ONLY**

Facility # 2023173  
Permit # 01218-2020INS  
Request Rec'd 08/26/2020  
Amended Date  
Approval Date 8/31/2020  
Permit Expires 3/3/2021

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Graham Enterprise, Inc. 750 Bunker Court Vernon Hills, IL 60061  Contact: John Graham (847) 837-0777	<b>(2) FACILITY</b> - name and address where tanks are located:  Rock N Roll BP 157 631 North LaSalle Street Chicago, IL 60610  Contact: Shakeel Khan (312) 943-3628
---	--

**(3) INSTALLATION OF TANKS:**

- (a) Number and size of tanks being installed: (TK # 5) - 30,000, (TK # 6) - 15,000, (TK # 7, 8) - 7,000*
- (b) Type of tank(s): (TK # 5, 6, 7, 8) Tank - Fiberglass Double Wall Containment Solutions*
- (c) Type of piping: (TK # 5, 6, 7, 8) Piping - Flexible Double Wall NUPI Smartflex*
- (d) Product to be stored in each tank: (TK # 5, 6) - Gasoline, (TK # 7) - Bio-Diesel, (TK # 8) - E-85*
- (e) Type of leak detection being used:*
  - Tank: (TK # 5, 6, 7, 8) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring*
  - Piping: (TK # 5, 6, 7, 8) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 5, 6, 7, 8) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown*
- (f) Corrosion Protection being used:*
  - Tank: (TK # 5, 6, 7, 8) Corrosion Prot - Tank - Fiberglass Non-Corrosive*
  - Piping: (TK # 5, 6, 7, 8) Corrosion Prot - Piping - Flexible Non-Corrosive*
- (g) Spill containment devices, piping and dispenser containment devices: (TK # 5, 6, 7, 8) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 5, 6, 7, 8) Overfill Prev Device - Overfill Drop Tube Valve, (TK # 5, 6, 7, 8) Overfill Prev Device - Overfill Alarm*

- (4)** The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Performance Tank, Inc.  
730 Creel Drive  
Wood Dale, IL 60191

Contact Person: Tim Berg  
Phone: (630) 860-9500  
Contractor Registration # IL881 Exp. 11/21/2020

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist  
Division File