



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2021423
Permit # 01237-2020UPG
Request Rec'd 09/01/2020
Amended Date
Approval Date 9/1/2020 DS
Permit Expires 9/14/2020

Permit for Emergency Repair Request on 8/31/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Super Properties, Inc. 17500 S. Dixie Hwy. Homewood, IL 604301234 Contact: Aqil Jaade (773) 251-3018	(2) <u>FACILITY</u> - name and address where tanks are located: Man Choice, Inc. d/b/a Mobil Gas & Food 17500 South Dixie Highway Homewood, IL 60430 Contact: Aqil Jaade (773) 251-3018
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 8,000, (TK # 3) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Premium, (TK # 2, 3) - Gasoline - Regular*
- (e) *Type of leak detection being used:*
- Tank:*
- Piping:*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

WE ARE FIXING REGULAR AND PREMIUM LINE BETWEEN 5,6 AND 7,8 DISPENSER LINE IS BROKEN

NOTE: If repairs are more than 20' of piping or more than 50% of the piping run between dispensers then the entire run must be replaced with double wall piping with sensors installed in both dispenser sumps. This will need to be done under a separate upgrade permit.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


America Petropump Services LLC d/b/a Ampsco Services

Contact Person: Kiran Patibandla

4075 Fox Valley Center Dr., Unit 9
Aurora, IL 60504

Phone: (630) 649-8699
Contractor Registration # IL002420 Exp. 5/22/2021

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File