



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

<u>FOR OFFICE USE ONLY</u>
Facility # 2-012966
Permit # 01877-2007INS
Request Rec'd 11/07/2007
Amended Date
Approval Date 11/8/2007 JC
Permit Expires 5/8/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Graham C-Stores Company 33978 N. Highway 45, P.O. Box 89 Gages Lake, IL 60030-0089</p> <p>Contact: Mike Graham (847) 223-3710</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Gages Lake Citgo 33978 N Hwy 45 Gages Lake, Lake Co., IL</p> <p>Contact: Jack Graham (847) 223-3710</p>
---	---

(3) INSTALLATION OF TANKS:

- (a) **Number and size of tanks being installed:** (TK # 8) - 10,000 gallons, (TK # 9) - 2,000 gallons
- (b) **Type of tanks:** (TK # 8, 9) - (Installing) Glasteel II double wall composite
- (c) **Type of piping:** (TK # 8, 9) - (Installing) partial A.O. Smith double wall fiberglass to hook into the existing lines that were being served by tanks #2 and #4 at approximately the northern edge of the tank field for tanks 5 & 7., (TK # 8, 9) - Existing partial single wall fiberglass to remain
- (d) **Product to be stored in each tank:** (TK # 8) - Diesel Fuel, (TK # 9) - Kerosene
- (e) **Type of leak detection being used:**
 - Tank:** (TK # 8, 9) - Existing automatic tank gauging from discontinued system to be re-used
 - Piping:** (TK # 8) - Existing line leak detector from discontinued system to be re-used, (TK # 9) - (Installing) European Suction
- (f) **Corrosion Protection being used:**
 - Tank:** (TK # 8, 9) - (Installing) Composite
 - Piping:** (TK # 8, 9) - Existing partial fiberglass, (TK # 8, 9) - (Installing) partial Fiberglass
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES: Tank #4 is converting from diesel to E-85, and tanks 1,2,3 are being taken out of service.

<p>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	<p>Contact Person: Ray Kirchner Phone: Contractor Registration # Exp. 06/21/2008</p>
--	--

Sincerely,

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 1/98)