

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

#### **Division of Technical Services**

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

# FOR OFFICE USE ONLY

Facility # 1-028139
Permit # 01858-2007UPG
Request Rec'd 11/06/2007
Amended Date
Approval Date 11/7/2007 JC
Permit Expires 5/7/2008

## Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

ATTROVAL DATE.		
(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:	
KRKH Investments, Inc. 199 Sherwood Drive Wood Dale, IL 60191	Marathon 3299 S. Alpine, Alpine Road & Mayflower Avenue Rockford, Winnebago Co., IL	
Contact: Shilu Anin (630) 595-6032	Contact: Phillip Dittamore	

### (3) <u>UPGRADE OR REPAIR OF TANKS:</u>

- (a) Number and size of tanks being upgraded or repaired: (TK # 3, 4) 10,000 gallons
- (b) Type of tanks:
- (c) Type of piping:
- (d) Product to be stored in each tank: (TK # 3, 4) Gasoline
- (e) Type of leak detection being used:

Tank:

**Piping:** (TK # 3, 4) - (Installing) Veeder Root TLS350 electronic line leak detector for the "main" product line only (the piping for these two tanks are manifolded together, with the line from tank #3 being the "main" line). Contractor states only one line leak detector will be installed and it will monitor both lines.

(f) Corrosion Protection being used:

Tank:

Piping:

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at <a href="https://www.state.il.us/osfm">www.state.il.us/osfm</a> or by calling (217)785-1020.

#### (5) **SPECIAL CONTINGENCIES**:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:		
	Contact Person: Nate Meyer	
	Phone:	
	Contractor Registration # IL-1890	Exp.

Sincerely,

cc: Storage Tank Safety Specialist -

Fire Department - Office Coordinator -

Division File

(Rev. - 1/98)

Janu J Affey