



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
 Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
 Facility # 2-012966
 Permit # 01434-2007REL
 Request Rec'd 09/11/2007
Amended Date 10/31/2007
 Approval Date 9/11/2007 JC
 Permit Expires 3/11/2008

Amended

Permit for INTERIOR LINING of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to internally line underground storage tank(s) or piping is hereby granted. Such interior lining must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. Such interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Graham C-Stores Company 33978 N. Highway 45, P.O. Box 89 Gages Lake, IL 60030-0089</p> <p>Contact: Mike Graham (847) 223-3710</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Gages Lake Citgo 33978 N Hwy 45 Gages Lake, Lake Co., IL</p> <p>Contact: Jack Graham (847) 223-3710</p>
---	---

(3) INTERIOR LINING OF TANKS:

- (a) *Number and size of tanks being internally lined:* (TK # 1, 2, 3, 4) - 5,000 gallons
 - (b) *Type of tanks:*
 - (c) *Name of manufacturer of internal lining material:* (TK # 1, 2, 3, 4) Armor Shield
 - (d) *Designation of internal lining material:* (TK # 1, 2, 3, 4) TL 300M
 - (e) *Product to be stored in each tank:* (TK # 1) - Gasoline, (TK # 2) - Kerosene, (TK # 3) - E-85, (TK # 4) - Diesel Fuel
 (Internal lining material must be compatible with product stored in each tank)
 - (f) *Manway accessible at grade:*
- (4) **This permit is VOID if tank is unacceptable for interior lining. Any tank that has been out of service for a twelve month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for interior lining and manway installation only. Separate permits are required to do interior tank lining inspections.**
- (5) **The owner must notify this Office when completion of tank internal lining has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**
- (6) **SPECIAL CONTINGENCIES:** Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by sections 170.430(a)(1)(C) and (D), 170.430(b)(5), and 170.430(c)(10). **Amendment request to include tanks 1, 2, and 4 was received 10/31/07.** The underground storage tank system for tank #3 must be compatible with E-85, as indicated in section 170.470, 170.500, 170.530(d)(2), 170.530(j), and 170.540(a) of Title 41 of the Illinois Administrative Code, and as indicated in policy #06-PCS-005 regarding the use of alternative fuels in underground storage tanks.

<p>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>Bolin Enterprises, Inc.</p>	<p>Contact Person: Scott Justice Phone: Contractor Registration # Exp.</p>

Sincerely,

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 1/98)