



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 4000247
Permit # 01280-2020UPG
Request Rec'd 09/10/2020
Amended Date
Approval Date 9/14/2020 DS
Permit Expires 3/16/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Gilman Landco, LLC 2275 Half Day Road, Suite 127 Bannockburn, IL 60015 Contact: Schwalb (312) 282-1060</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Fred's Fuel 'n Food Mobil #2 620 US Highway 24 West Gilman, IL 60938 Contact: Denise Futrell (815) 383-4001</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3, 4, 6, 7) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 1, 3, 6) - Diesel Fuel, (TK # 2) - Bio-Diesel, (TK # 4, 7) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2, 3, 4, 6, 7) Spill Contain Device - Single Wall Spill Bucket Insert*
- (h) Overfill prevention devices: (TK # 1, 2, 3, 4, 6, 7) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) SPECIAL CONTINGENCIES :

Installing new OPW 71SO-410C overfill devices and knocking out the ball vavles. Installing new SW inserts on all spillages SCL-EBW-705

NOTE: Drop tubes must be set at 90% shut off

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Pemco Service Company, Inc. 1040 East Second Street	Contact Person: William "Butch" VonDrehle

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File