



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 1023129  
Permit # 01328-2020UPG  
Request Rec'd 09/17/2020  
Amended Date  
Approval Date 9/17/2020 DS  
Permit Expires 3/17/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Kelley Williamson Company 1132 Harrison Avenue Rockford, IL 61104  Contact: Bob Sanders (815) 397-9410</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Winnebago Mobil 903 N. Elida Street Winnebago, IL 61088  Contact: Aaron Rorabaugh (815) 387-6243</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 8) - 8,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 8) Piping - Flexible Double Wall A.P.T. Poly Tech between the existing dispenser and the new dispenser; (TK # 8) Piping - Shear Valves*
- (d) *Product to be stored in each tank: (TK # 8) - Diesel Fuel*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 8) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in existing dispenser sump as well as in new dispenser where new piping run in being installed*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : New canopy to be installed over diesel fueling area. A new diesel dispenser will be installed at the location shown on the plans. Piping between the existing dispenser and the new dispenser will be double wall flexible piping. New single wall fiberglass dispenser sumps will be installed below both dispensers. Existing single wall fiberglass piping between the tank and the existing dispenser will remain.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**


Oil Equipment Company, Inc.

Contact Person: TJ Winkler

4701 Lien Road  
Madison, WI 53704

Phone: (608) 249-2881  
Contractor Registration # IL1318 Exp. 10/29/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File