



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4008047
Permit # 01330-2020REM
Request Rec'd 09/17/2020
Amended Date
Approval Date 9/21/2020 DS
Permit Expires 3/23/2021

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| | |
|--|---|
| <p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Wortman-Meyer Properties, LLC 1502 W. Fayette Effingham, IL 62401 Contact: Lisa Wortman (217) 342-7291</p> | <p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Holiday Jack Flash 1502 West Fayette Avenue Effingham, IL 62401 Contact: Hillary Sedam (217) 342-4043</p> |
|--|---|

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 6) - 10,000, (TK # 7, 8) - 12,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Removal of STP sumps, UDC sumps, product pipe, canopy, islands, dispensers, spill buckets, and sump sensors for installation of all new equipment. Tanks and vent piping to remain.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2022

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File