



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 7020182
Permit # 01339-2020UPG
Request Rec'd 09/18/2020
Amended Date
Approval Date 9/21/2020 DS
Permit Expires 3/23/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Fehrenbacher Enterprises, Inc. P.O. Box 862 1402 South West Olney, IL 62450</p> <p>Contact: Bart Fehrenbacher (618) 392-7941</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Red Rooster Truck Stop Route 50 & 130 1402 So. West St. Olney, IL 62450</p> <p>Contact: Bart Fehrenbacher (618) 392-7941</p>
-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 20,000, (TK # 6) - 12,000, (TK # 7) - 4,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5, 6, 7) Piping - Flexible Double Wall A.P.T. Poly Tech P150SC from existing dispensers to new dispensers as shown in site plan*
- (d) *Product to be stored in each tank: (TK # 5) - Diesel Fuel, (TK # 6) - Gasoline - Regular, (TK # 7) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
- Tank:*
- Piping: (TK # 5, 6, 7) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in existing and new dispenser sumps*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Adding 2 Gilbarco 700S dispensers at car islands. Installing APT XP-150-SCC dual wall piping OPW DS 1836 dispenser sumps and Veeder Root 794380-208 sump sensors. Canopy will be added on to existing canopy. New islands will be poured.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Pemco Service Company, Inc.
1040 East Second Street
Gilman, IL 60938

Contact Person: William "Butch" VonDrehle
Phone: (815) 265-7364

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File