



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 4008047  
Permit # 01344-2020UPG  
Request Rec'd 09/17/2020  
Amended Date  
Approval Date 9/21/2020 DS  
Permit Expires 3/23/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Wortman-Meyer Properties, LLC 1502 W. Fayette Effingham, IL 62401  Contact: Lisa Wortman (217) 342-7291	<b>(2) FACILITY</b> - name and address where tanks are located:  Holiday Jack Flash 1502 West Fayette Avenue Effingham, IL 62401  Contact: Hillary Sedam (217) 342-4043
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 6) - 10,000, (TK # 7, 8) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 6, 7, 8) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from existing tanks to new dispensers as shown in site plan, (TK # 6, 7, 8) Piping - Other Submersible Pump, (TK # 6, 7, 8) Piping - Ball Valves, (TK # 6, 7, 8) Piping - Shear Valves, (TK # 6, 7, 8) Piping - Flex Connector Steel, (TK # 6, 7, 8) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 6) - Diesel Fuel, (TK # 7) - Gasoline - Regular, (TK # 8) - Gasoline - Premium*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 6, 7, 8) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in all submersible and dispenser sumps*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices: (TK # 6, 7, 8) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 6, 7, 8) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Will be installing all new sumps, product piping, sump sensors, dispensers, tank top equipment, and canopy. Tanks and vent piping to remain in place. Replaced piping exceeds 20 feet or 50% of the total pipe run.

**NOTE: Existing ball floats to be removed or disabled. If disabled the drop tubes must be set at 90% shut off**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
St. Louis, MO 63139

Contact Person: Jimmy Spiros  
Phone: (314) 772-4501  
Contractor Registration # IL1502 Exp. 3/26/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File