



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2036210  
Permit # 01360-2020UPG  
Request Rec'd 09/24/2020  
Amended Date  
Approval Date 9/24/2020 DS  
Permit Expires 3/24/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  American Domestic Oil, Inc. 715 West Roosevelt Road Maywood, IL 60153  Contact: Saji Varkey (708) 450-1550	<b>(2) FACILITY</b> - name and address where tanks are located:  Roosevelt Citgo 715 West Roosevelt Maywood, IL 60153  Contact: Sunny Kurian 7084501550
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 7) - 12,000, (TK # 8) - 6,000, (TK # 9) - 5,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 7, 8, 9) Piping - Flexible Double Wall OPW Flexworks from existing tanks to dispensers as shown in site plan, (TK # 7, 8, 9) Piping - Ball Valves, (TK # 7, 8, 9) Piping - Shear Valves, (TK # 7, 8, 9) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 7, 8) - Gasoline, (TK # 9) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping: (TK # 7, 8, 9) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 7, 8, 9) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 7, 8, 9) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Replaced piping exceeds 20 feet or 50% of the total pipe run.

**NOTES:** Site has existing sump sensors, but they must be wired for positive shut down. There are no existing ball floats to be removed/disabled.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Contact Person: Robert Stenstrom

Stenstrom Petroleum Services Group  
2422 Center Street  
Rockford, IL 61108

Phone: (815) 398-6250  
Contractor Registration # IL1890 Exp. 4/12/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File