



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 4012122  
Permit # 01398-2020UPG  
Request Rec'd 10/02/2020  
Amended Date  
Approval Date 10/5/2020 DS  
Permit Expires 4/6/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Evergreen FS, Inc. P.O. Box 1367 Bloomington, IL 61702  Contact: Bob Eichelberger (309) 663-2392</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>F S Farmtown 1808 Morrissey Bloomington, IL 61704  Contact: Bob Eichelberger (309) 662-9321</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 6, 7) - 10,000, (TK # 8) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 6) - Diesel Fuel, (TK # 7) - Gasoline - Regular, (TK # 8) - E-85*
- (e) Type of leak detection being used:*
  - Tank: (TK # 6, 7, 8) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 300c with CSLD*
  - Piping: (TK # 6, 7, 8) Leak Detect - Piping - Non-Discriminating Sump Sensor*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Replacing existing Incon TS1001 ATG with Veeder Root TLS 300C ATG with CSLD. Also replacing existing Incon sump sensors with Veeder Root non-discriminating sensors. Replacing existing Incon leak detection probes with Veeder Root Mag Plus probes to be compatible with monitored products.

**NOTE: Sensors must be wired for positive shut down**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Contact Person: William "Butch" VonDrehle

Pemco Service Company, Inc.  
1040 East Second Street  
Gilman, IL 60938

Phone: (815) 265-7364  
Contractor Registration # IL1224 Exp. 2/26/2022

Sincerely,



Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File