



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453162

FOR OFFICE USE ONLY

Facility # 2047121
Permit # 01428-2020REM
Request Rec'd 10/07/2020
Amended Date
Approval Date 10/7/2020
Permit Expires 4/8/2021

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: 1530 N State Parkway Building Corporation 1530 N State Parkway Chicago, IL 60610 Contact: Dean Lerner (312) 706-2324	(2) <u>FACILITY</u> - name and address where tanks are located: 1530 N State Parkway Building Corporation 1530 N State Parkway Chicago, IL 60610 Contact: Dean Lerner (312) 706-2324
--	--

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 1) - 7,500*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 1) - #2 Fuel Oil*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 1) - 12/31/1973*

- (4)** The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.


(5) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Orivne, Inc.
55 East Monroe Street, Suite 3800
Chicago, IL 60603

Contact Person: Mike Leyden
Phone: (312) 656-2009
Contractor Registration # IL002408 Exp. 5/1/2021

Sincerely,


Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File