

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety 1035 Stevenson Drive Springfield, IL 62703 2177851020

FOR OFFICE USE ONLY

Facility # 1015668 Permit # 01457-2020UPG Request Rec'd 10/09/2020 Amended Date Approval Date 10/13/2020 DS Permit Expires 4/13/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
1305 12th Avenue Rock Falls, IL 61071	Express Lane Shell 342 North Mason Amboy, IL 61310 Contact: Tabitha Berogan (815) 625-6380
Contact: Kathy Peugh (815) 625-6380	

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 6) 4,000, (TK # 7) 12,000
- (b) Type of tanks:
- (c) Type of piping: (TK # 6, 7) Piping Flexible Double Wall A.P.T. Poly Tech S175SC from existing transition sump to 3 new dispensers as shown in site plan, (TK # 6, 7) Piping Shear Valves
- (d) Product to be stored in each tank: (TK # 6) Gasoline Premium, (TK # 7) Gasoline Regular
- (e) Type of leak detection being used:

Tank:

Piping: (TK # 6, 7) Leak Detect - Piping - Non-Discriminating Sump Sensor in all dispenser sumps

NOTES: Existing transition sump has existing sensor already. Sensors MUST be wired for positive shut down.

(f) Corrosion Protection being used:

Tank:

Piping:

- (g) Spill containment devices, piping, and dispenser containmnt devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfmillinois.gov or by calling (217)785-1020.

(5) <u>SPECIAL CONTINGENCIES</u> :

Replaced piping exceeds 20 feet or 50% of the total pipe run.

NOTE: Dispensers MUST maintain a full 10' from all property lines and buildings per 175.450

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: JC Cline Phone: (309) 762-1729 Contractor Registration # IL981 Exp. 5/1/2022

Sincerely,

Daniel J. Starks

Daniel Starks

cc: Storage Tank Safety Specialist Division File