



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2033446
Permit # 01458-2020REM
Request Rec'd 10/12/2020
Amended Date
Approval Date 10/13/2020 DS
Permit Expires 4/13/2021

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Saint Charles Resort, LLC 4051 East Main Street St. Charles, IL 60174</p> <p>Contact: Nick Kolb (630) 524-5066</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Pheasant Run Resort 4051 E Main St St. Charles, IL 60174</p> <p>Contact: Mirkes Pete (630) 584-6300</p>
--	---

(3) REMOVAL OF TANKS:

- (a) Number and size of tanks being removed: (TK # 3) - 2,000, (TK # 4) - 1,000*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 3) - Gasoline - Regular, (TK # 4) - Diesel Fuel*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 3, 4) - Unknown*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES : Removal of complete fueling systems.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Orivne, Inc. 55 East Monroe Street, Suite 3800 Chicago, IL 60603</p>	<p>Contact Person: Mike Leyden Phone: (312) 656-2009 Contractor Registration # IL002408 Exp. 5/1/2021</p>

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File