



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 5047128  
Permit # 01471-2020REM  
Request Rec'd 10/06/2020  
Amended Date  
Approval Date 10/14/2020 DS  
Permit Expires 4/14/2021

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>City of Jacksonville 200 West Douglas Jacksonville, IL 62650</p> <p>Contact: les ballenger (217) 370-2477</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>City of Jacksonville ROW 302 1/2 East State Rd Jacksonville, IL 62650</p> <p>Contact: Andy Ezard (217) 479-4610</p>
--	--

**(3) REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 1) - 1,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1) - #2 Fuel Oil*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 1) - 12/31/1973*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**(5) SPECIAL CONTINGENCIES :**

Subject UST was encountered during a planned water main upgrade project for the City of Jacksonville.

Work shall consist of removing approximately 400 gallons of water/fuel oil residue, purge UST of flammable vapors, remove UST from excavation, cut/clean UST, and dispose of UST and all associated piping at a local metal recycling center. Western shall collect sidewall and floor samples and submit with the associated Site Assessment Report.

Following removal activities the City of Jacksonville shall complete water main installation and backfill the area with granular material (sand) and complete planned project activities.

Should there be additional questions feel to contact:

Tony Jachino

Western Asphalt, Inc.

217-652-1452 (Cell)

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Western Asphalt, Inc.  
2665 Prairie College Road  
Jacksonville, IL 62650

Contact Person: Tony Jachino  
Phone: (217) 243-3822  
Contractor Registration # IL374 Exp. 4/25/2022

Sincerely,

*Daniel H. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File