



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1039830
Permit # 01494-2020REM
Request Rec'd 10/16/2020
Amended Date
Approval Date 10/19/2020 DS
Permit Expires 4/20/2021

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Kelley Williamson Company 1132 Harrison Avenue Rockford, IL 61104 Contact: Bob Sanders (815) 397-9410</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Wheeler Road Mobil 5955 Wheeler Road Cherry Valley, IL 61016 Contact: Melissa Bragg (815) 332-5600</p>
---	--

(3) **REMOVAL OF PIPING:**

(a) *Description/location of piping being removed:*

(b) *Which tank(s) are associated with the piping being removed: (TK # 1) - 12,000, (TK # 2, 3) - 8,000*

(c) *Reason of piping being removed:*

(d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Remove existing pipe from the tank top to all five islands for regular and premium products. Diesel was piped to the gas islands for future use. We will remove the diesel piping to gas islands back to tank top where piping is manifolded. The regular and the premium STP sumps will be removed.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 3/7/2022

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File