



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2013987
Permit # 01532-2020UPG
Request Rec'd 10/21/2020
Amended Date
Approval Date 10/26/2020 DS
Permit Expires 4/27/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>3720 South Cicero, LLC 3720 S. Cicero Ave. Stickney, IL 60804</p> <p>Contact: Zbigniew Zolnierzow (708) 516-4474</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Truckquest, Inc. 3738 S. Cicero Ave. Stickney, IL 60804</p> <p>Contact: Yovanhitt (708) 516-4474</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 1, 10) - 8,000, (TK # 9) - 12,000, (TK # 11) - 4,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(TK # 1, 9, 10, 11) Piping - Flexible Double Wall NUPI Smartflex from existing tanks to dispensers as shown in site plan, (TK # 1, 9, 10, 11) Piping - Single Wall STP/Tanktop Sump

NOTE: Dispensers MUST maintain a full 10' from buildings and property lines

(d) *Product to be stored in each tank: (TK # 1, 9) - Diesel Fuel, (TK # 10) - Gasoline - Regular, (TK # 11) - Gasoline - Premium*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 1, 9, 10, 11) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection, (TK # 1, 9, 10, 11) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in all submersible and dispenser sumps

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 9, 10, 11) Spill Contain Device - Single Wall Spill Bucket*

(h) *Overfill prevention devices: (TK # 1, 9, 10, 11) Overfill Prev Device - Overfill Drop Tube Valve*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replaced piping exceeds 20 feet or 50% of the total pipe run.


NOTE: A removal permit MUST be obtained for the piping

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

CAT Builders USA, Inc.
522 E. Dundee Road
Palatine, IL 60074

Contact Person: Jan kopytek
Phone: (630) 670-6280
Contractor Registration # IL002381 Exp. 3/12/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File