



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 6007986
Permit # 01293-2020UPG
Request Rec'd 09/14/2020
Amended Date 11/05/2020 DS
Approval Date 9/14/2020 DS
Permit Expires 3/16/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Fadi's Oil Investment, Inc. 7311 Old St. Louis Road Belleville, IL 62223 Contact: Hassan A. Daoud (618) 397-2199	(2) <u>FACILITY</u> - name and address where tanks are located: Belleville Quick Shop 7311 Old St Louis Road Belleville, IL 62223 Contact: Omar Isa (618) 397-2199
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 8, 9, 10) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 8, 9, 10) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L, (TK # 8, 9, 10) Piping - Other Steel Riser, (TK # 8, 9, 10) Piping - Ball Valves, (TK # 8, 9, 10) Piping - Flex Connector Steel, (TK # 8, 9, 10) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 8) - Gasoline - Regular, (TK # 9) - Gasoline - Premium, (TK # 10) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 8, 9, 10) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 8, 9, 10) Spill Contain Device - Single Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 8, 9, 10) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :


Amendment Reason: Replacing all STP sumps and all STP's. Will have to cut back small portion of product pipe to remove STP sumps. Will also replace ball valves and flex connectors within the STP sumps. Will be replacing mechanical leak detectors as part of the new STP's. Removed ball floats from all No Lead, Premium and Diesel tanks.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File