



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1027928
Permit # 01594-2020REM
Request Rec'd 11/05/2020
Amended Date
Approval Date 11/5/2020 DS
Permit Expires 5/5/2021

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Johnson Oil Company 1305 12th Avenue Rock Falls, IL 61071 Contact: Kathy Peugh (815) 625-6380</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Shabbona Amoco 515 East Comanche Shabbona, IL 60550 Contact: Bridget Staten (815) 496-2387</p>
---	--

(3) **REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 1, 2) - 12,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Premium*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 1, 2) - Unknown*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES :**

We are removing the old fuel islands and replacing with new
Removing the old Ameron FRP doublewall piping to make way for new APT piping and UDC's.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Illowa Enterprises, Inc.
2703 4th Avenue
Moline, IL 61265

Contact Person: JC Cline
Phone: (309) 762-1729
Contractor Registration # IL981 Exp. 5/1/2022

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File