



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 5034304  
Permit # 01653-2020UPG  
Request Rec'd 11/17/2020  
Amended Date  
Approval Date 11/18/2020 DS  
Permit Expires 5/18/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Harry and Doris Alton, Trustees of Alton Family Trust P.O. Box 8825 Springfield, IL 62781</p> <p>Contact: Elizabeth Patterson (217) 546-6858</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Mac's Convenience Stores, LLC d/b/a Bigfoot #140 1201 Toronto Road Springfield, IL 62794</p> <p>Contact: Charlene Troyer (331) 251-7343</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2, 3) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L, (TK # 1, 2, 3) Piping - Shear Valves*
- (d) Product to be stored in each tank: (TK # 1, 2) - Gasoline - Regular, (TK # 3) - Gasoline - Premium*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

installation of new dispenser sump to allow installation of new shear valves, this will require cutting back single wall pipe and installing new single wall pipe into the new sump. Replacement of the shear valves to replace to make all shear valves in proper working order per NOV E0020202730.

Will also be installing two emergency stops on the canopy columns at dispenser 1/2 and 5/6 to correct issue on NOV E0020202731.

Circle K to be hiring Tanknology to install cathodic protection at Tank #3 STP sump on NOV E0020202730.

Circle K to be hiring Tanknology to perform Annual Walkthrough Inspection on NOV E0020202730.


Open electrical conduit or junction box on Tank #1 ATG Probe Riser has been repaired for NOV 0020202730

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
St. Louis, MO 63139

Contact Person: Jimmy Spiros  
Phone: (314) 772-4501  
Contractor Registration # IL1502 Exp. 3/26/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File