



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

**FOR OFFICE USE ONLY**

Facility # 2024727  
Permit # 01314-2020INS  
Request Rec'd 09/02/2020  
Amended Date 11/24/2020 DS  
Approval Date 9/16/2020 DS  
Permit Expires 3/16/2021

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>City of Waukegan 100 North Martin Luther King, Jr. Avenue Waukegan, IL 60085</p> <p>Contact: Brent Dominowski (847) 625-6852</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Public Works Facility 1700 McAree Road Waukegan, IL 60085</p> <p>Contact: Brent Dominowski (847) 625-6831</p>
---	--

**(3) INSTALLATION OF TANKS:**

- (a) *Number and size of tanks being installed: (TK # 11, 13) - 10,000*
- (b) *Type of tank(s): (TK # 11, 13) Tank - Fiberglass Double Wall ZCL, USA Prezerver*
- (c) *Type of piping: (TK # 11, 13) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from tanks to dispensers as shown in site plan, (TK # 11, 13) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 11) - Gasoline - Regular, (TK # 13) - Diesel Fuel*
- (e) *Type of leak detection being used:*
  - Tank: (TK # 11, 13) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus, (TK # 11, 13) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring*
  - Piping: (TK # 11, 13) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 11, 13) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown in all submersible and dispenser sumps*
- (f) *Corrosion Protection being used:*
  - Tank: (TK # 11, 13) Corrosion Prot - Tank - Fiberglass Non-Corrosive*
  - Piping: (TK # 11, 13) Corrosion Prot - Piping - Fiberglass Non-Corrosive*
- (g) *Spill containment devices, piping and dispenser containment devices: (TK # 11, 13) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices: (TK # 11, 13) Overfill Prev Device - Overfill Drop Tube Valve, (TK # 11, 13) Overfill Prev Device - Overfill Alarm*

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) by calling (217)785-1020.
- (5) **GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) **SPECIAL CONTINGENCIES :**

Amendment Reason: Need to update TANK 12 from Gasoline Mid-Grade to Gasoline Regular Changing the TLS-530 and replacing it with a NEW Veeder Root TLS-450Plus Updating TLS350 to New Veeder Root tls-450PLus


**NOTE: No changes were needed per the contractor as the proper equipment was listed from previous amendment**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

U.S. Venture, Inc.  
425 Better Way  
Appleton, WI 54915

Contact Person: Larry Smarzinski  
Phone: (920) 735-8249  
Contractor Registration # IL002403 Exp. 4/11/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File