



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2033566  
Permit # 01691-2020UPG  
Request Rec'd 11/25/2020  
Amended Date  
Approval Date 11/25/2020 DS  
Permit Expires 5/25/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Commonwealth Edison/Exelon Corporation 3 Lincoln Center - Real Estate &amp; Facilities Oakbrook Terrace, IL 601814260  Contact: Michael Grazioli (630) 303-2681</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Corporate Computer Center 1700 Spencer Road Joliet, IL 604338569  Contact: Josh Walter (630) 688-4409</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 20,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2) Piping - Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping from existing tanks to transition sumps, (TK # 1, 2) Piping - Anti-siphon Valves OPW 99ASV-2200, (TK # 1, 2) Piping - Ball Valves, (TK # 1, 2) Piping - Valves Foot Valve, (TK # 1, 2) Piping - Flex Connector Steel, (TK # 1, 2) Piping - Double Wall STP/Tanktop Sump, (TK # 1, 2) Piping - Double Wall Transition Sump*
- (d) *Product to be stored in each tank: (TK # 1, 2) - Diesel Fuel*
- (e) *Type of leak detection being used:*
- Tank:*
- Piping: (TK # 1) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 1, 2) Leak Detect - Piping - Discriminating Sump Sensor with positive shutdown in submersible and transition sumps, (TK # 2) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2) Spill Contain Device - Single Wall Spill Bucket*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Replaced piping exceeds 20 feet or 50% of the total pipe run.

**NOTE: A removal permit must be obtained for the existing piping to be removed**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

MZI Group, Inc.  
1937 W Fulton St  
Chicago, IL 60612

Contact Person: Raul Romero  
Phone: (312) 492-8740  
Contractor Registration # IL002447 Exp. 5/7/2022

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File