

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 2177851020

FOR OFFICE USE ONLY

Facility # 6007982 Permit # 01712-2020INS Request Rec'd 11/25/2020 Amended Date Approval Date 12/2/2020 DS Permit Expires 6/2/2021

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:

HPT TA Properties, LLC

24601 Center Ridge Road Westlake, OH 44145

Contact: Rob Porges (440) 808-7268

(2) FACILITY - name and address where tanks are located:

Travel Centers of America 819 Edwardsville Road I-55 & I-70 & State Route 162 Troy, IL 62294

Contact: Jim Schenker (440) 808-7368

(3) <u>INSTALLATION OF TANKS:</u>

- (a) Number and size of tanks being installed: (TK # 14) 1,000
- (b) Type of tank(s): (TK # 14) Tank Composite Double Wall Glasteel II
- (c) Type of piping: (TK # 14) Piping Fiberglass Single Wall Piping A.O. Smith, (TK # 14) Piping Single Wall STP/Tanktop Sump
- (d) Product to be stored in each tank: (TK # 14) Used Oil
- (e) Type of leak detection being used:

Tank: (TK # 14) Leak Detect - Tank - Automatic Tank Gauging, (TK # 14) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring

Piping: (TK # 14) Leak Detect - Piping - Gravity Feed

(f) Corrosion Protection being used:

Tank: (TK # 14) Corrosion Prot - Tank - Fiberglass Non-Corrosive

Piping: (TK # 14) Corrosion Prot - Piping - Gravity Feed

- (g) Spill containment devices, piping and dispenser containment devices: (TK # 14) Spill Contain Device Double Wall Spill Bucket
- (h) Overfill prevention devices: (TK # 14) Overfill Prev Device Less than 25 gallon fills
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.govor by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS: There shall be a minimum of two manufactured slotted or perforated observation wells of at lease 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES:

Installation of new Glassteel double wall 1,000 gallon Used Oli tank to complete NOV requirements. See below itemized detail.

Removing existing UST 1000 gallon per NOV

Excavation of tank hole 1 to 1 sloping

Stockpile soil onsite for future disposal at landfill after testing.

Bed and set owner provided 1,000-gallon double-wall tank.

Installation of owner provided tank sump, extractor, double-wall spill containment and entry fittings.

Provide and install one (1) new probe riser, spill containment riser and vent riser.

Extend existing drain line at the building to the new tank sump.

Installation of a new vent line from the tank to the building.

Perform the required state inspection, tank air test, primary line test, hydrostatic test and the final inspection.

Provide 275 tons of backfill material.

Perform the tank and line tests.

Install new conduit from the existing tank monitor conduit, which was cut back during the tank removal. Loop the conduit for the tank inventory probe, and interstitial sensor.

Pull one (1) new Beldon shield cables from the tank location through the existing conduit to the Veeder-Root location.

NIMCO assumes that the cables can be pulled through the existing home run with ease.

Use the existing modules within Veeder-Root, program and test.

NOTE: Tank #1 to be removed under a separate removal permit which will satisfy N.O.V.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Northern Indiana Mechanical 3311 East 15th avenue Gary, IN 46403 Contact Person: michael kiest Phone: (219) 963-1640

Contractor Registration # IL292 Exp. 3/25/2021

Sincerely,

Daniel Starks

Daniel J. Starks

cc: Storage Tank Safety Specialist Division File