



City of Chicago  
Department of Public Health  
333 South State Street, Room 200  
Chicago, IL 60604  
3127453162

**FOR OFFICE USE ONLY**

Facility # 2047163  
Permit # 01778-2020REM  
Request Rec'd 12/16/2020  
Amended Date  
Approval Date 12/16/2020  
Permit Expires 6/16/2021

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Chicago Department of Aviation 10510 West Zenke Road Chicago, IL 60666</p> <p>Contact: Aaron Frame (773) 686-3563</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Chicago O'Hare International Airport 10510 West Zenke Road Chicago, IL 60666</p> <p>Contact: Aaron Frame (773) 686-3563</p>
--	--

**(3) REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 1) - 1,500*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1) - #2 Fuel Oil*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 1) - 12/31/1973*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**(5) SPECIAL CONTINGENCIES :**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Meccon Industries  
2703 Bernice Road PO Box 206  
Lansing IL 60438

Contact Person: Greg Curran  
Phone: (708) 474-8300  
Contractor Registration # IL002429 Exp. 12/16/2022

Sincerely,

  
Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist  
Division File