



Office of the Illinois State Fire Marshal  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 2177851020

**FOR OFFICE USE ONLY**  
 Facility # 2021191  
 Permit # 01780-2020UPG  
 Request Rec'd 12/17/2020  
 Amended Date  
 Approval Date 12/17/2020 DS  
 Permit Expires 12/29/2020

**Permit for Emergency Repair Request on 12/17/2020**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Nickolas Kontos        7024 N. Keeler        Lincolnwood, IL 607122318</p> <p>Contact: Nickolas Kontos (847) 809-4200</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Rolling Meadows Shell, Inc.        2200 Algonquin Road        Rolling Meadows, IL 60008</p> <p>Contact: Nickolas Kontos (847) 809-4200</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 5) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5) Piping - Flexible Double Wall Environ Geo Flex*
- (d) Product to be stored in each tank: (TK # 5) - Gasoline - Premium*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Replacing a failed O-ring for the premium pipe in dispenser sump #1/2.

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>B &amp; K Equipment Company        2939 175th Street        Lansing, IL 60438</p>	<p>Contact Person: Ed Angell        Phone: (708) 474-3344        Contractor Registration # IL1207 Exp. 2/14/2022</p>

Sincerely,

*Daniel G. Starks*

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File