



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6043093
Permit # 01800-2020UPG
Request Rec'd 12/23/2020
Amended Date
Approval Date 12/23/2020 DS
Permit Expires 6/23/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Sasak Corporation 8711 St. Charles Rock Road St. John, MO 63114 Contact: Ankit Patel (314) 426-3115</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Alorton Crossing d/b/a Step N Go 4217 Old Missouri Avenue Alorton, IL 62207 Contact: Frank Khalil (618) 874-8392</p>
---	--

(3) **UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 8,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 2) Piping - Other Steel Riser, (TK # 2) Piping - Ball Valves, (TK # 2) Piping - Flex Connector Steel, (TK # 2) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 2) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Install new FRP STP sump. The existing flexible piping and STP will be reused. New ball valve and flex connector will be installed. The existing sump sensor will remain and programmed for positive shutdown.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

UPC Enterprises, LC d/b/a United Petroleum Service
4444 Union Blvd.
St. Louis, MO 63115

Contact Person: Terry Smith
Phone: (314) 241-3767
Contractor Registration # IL002402 Exp. 2/10/2022

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File