



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2013539  
Permit # 00011-2021UPG  
Request Rec'd 01/06/2021  
Amended Date  
Approval Date 1/6/2021 DS  
Permit Expires 7/7/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Hadi Inc. 8204 West 47th Street Lyons, IL 60534  Contact: Fouzia Hussain (708) 447-7320	<b>(2) FACILITY</b> - name and address where tanks are located:  Bob John's Citgo 8204 West 47th Street Lyons, IL 60534  Contact: Raza (708) 442-6016
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 6, 7) - 8,000, (TK # 13) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 6, 7, 13) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from existing tanks to existing dispenser locations as shown in site plan, (TK # 6, 7, 13) Piping - Other Submersible Pump, (TK # 6, 7, 13) Piping - Single Wall STP/Tanktop Sump*
- (d) *Product to be stored in each tank: (TK # 6) - Gasoline - Regular, (TK # 7) - Gasoline - Premium, (TK # 13) - Diesel Fuel*
- (e) *Type of leak detection being used:*  
  
*Tank:*  
  
*Piping: (TK # 6, 7, 13) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection*  
  
*NOTE: Existing sump sensors to be re-used, but they MUST be wired for positive shut down*
- (f) *Corrosion Protection being used:*  
  
*Tank:*  
  
*Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**


Replaced piping exceeds 20 feet or 50% of the total pipe run.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

America Petropump Services LLC d/b/a Ampsco Services  
4075 Fox Valley Center Dr., Unit 9  
Aurora, IL 60504

Contact Person: Kiran Patibandla  
Phone: (630) 649-8699  
Contractor Registration # IL002420 Exp. 5/22/2021

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File