



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3010676
Permit # 00058-2021UPG
Request Rec'd 12/18/2020
Amended Date
Approval Date 1/14/2021 DS
Permit Expires 7/14/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: US Government - Rock Island Arsenal/IMRI-PWE 1 Rock Island Arsenal/IMRI-PWE Rock Island, IL 61299 Contact: Reita Kuster (309) 788-2445	(2) FACILITY - name and address where tanks are located: Rock Island Arsenal 1 Rock Island Arsenal IMRI-PWE Rock Island, IL 61299 Contact: Reita Kuster (309) 788-2445
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 43) - 20,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 43) Piping - Single Wall STP/Tanktop Sump*

(d) *Product to be stored in each tank: (TK # 43) - Gasoline - Regular*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Remove and replace existing STP tank top sump due to leak at electrical penetrations

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Acterra Group, Inc.
200 35th Street
Marion, IA 52302

Contact Person: Tad Cooper
Phone: (319) 377-6357 Ext. 128
Contractor Registration # IL612 Exp. 10/26/2022

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File