



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 5020614
Permit # 00061-2021UPG
Request Rec'd 01/15/2021
Amended Date
Approval Date 1/19/2021 DS
Permit Expires 2/1/2021

Permit for Emergency Repair Request on 1/15/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>JIMV, Inc. 1028 N. 9th Street Springfield, IL 62702</p> <p>Contact: Inderjit Singh (917) 834-0996</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Gas Depot 1028 N. 9th Street Springfield, IL 62702</p> <p>Contact: Inderjit Singh (917) 834-0996</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 9) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 9) Piping - Flexible Double Wall Environ Geo Flex*
- (d) Product to be stored in each tank: (TK # 9) - Gasoline - Regular*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Removed leaking environ pipe fitting and replaced with new OPW pipe barb and clamshell. Perfomed precision test and mechanical line leak detector function test on this line.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>WJ Scott Company 3861 Tozer Road Springfield, IL 62707</p>	<p>Contact Person: Jim Scott Phone: (217) 787-6081 Contractor Registration # IL1949 Exp. 4/18/2022</p>

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File