



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4024557
Permit # 00088-2021UPG
Request Rec'd 01/21/2021
Amended Date
Approval Date 1/21/2021 DS
Permit Expires 7/21/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: BDS Oil Properties, LLC 3809 W. Russell Court Muncie, IN 47304 Contact: Japneet Khaira (765) 881-0511	(2) FACILITY - name and address where tanks are located: Quick Trip One, Inc. d/b/a Marshall Jiffy, Inc. 1804 N. Illinois Hwy 1 Marshall, IL 62441 Contact: Brian Davenport (812) 241-2247
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 8,600*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 5) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices: (TK # 5) Spill Contain Device - Single Wall Spill Bucket Insert*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Installing DPM SR-SCL-OPW-2100 spill container liner kit in OPW 2100 spill container on tank #5.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Pemco Service Company, Inc.
1040 East Second Street
Gilman, IL 60938

Contact Person: William "Butch" VonDrehle
Phone: (815) 265-7364
Contractor Registration # IL1224 Exp. 2/26/2022

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File