



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

**FOR OFFICE USE ONLY**  
 Facility # 2-021621  
 Permit # 01234-2012UPG  
 Request Rec'd 11/26/2012  
 Amended Date  
 Approval Date 11/27/2012 DS  
 Permit Expires 5/27/2013

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:           Thornton's, Inc.          10101 Linn Station Road, P.O. Box 34230          Louisville, KY 40223           Contact: Patty Leonhardt (800) 928-8022</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:           Thornton #7          2640 Mannheim Rd          Franklin Park, Cook Co., IL           Contact: Doug McGehee (847) 455-3066</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 5, 6, 7) - 12,000 gallons, (TK # 8, 9) - 6,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 5, 6, 7, 8, 9) - (Installing) Submersible Sumps containment FRP, (TK # 5, 6, 7, 8, 9) - (Installing) Dispenser Sumps containment FRP, (TK # 5, 6, 7, 8, 9) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX product piping
- (d) **Product to be stored in each tank:** (TK # 5, 6, 7) - Gasoline, (TK # 8) - Kerosene, (TK # 9) - Diesel Fuel
- (e) **Type of leak detection being used:**  
 Tank:  
 Piping: (TK # 5, 6, 7, 8, 9) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in all new dispenser sumps and submersible sumps
- (f) **Corrosion Protection being used:**  
 Tank:  
 Piping: (TK # 5, 6, 7, 8, 9) - (Installing) Fiberglass Non-Corrosive
- (g) **Spill containment devices, piping, and dispenser containment devices:** (TK # 5, 6, 7, 8, 9) - (Installing) Manhole Pre-manufactured EBW 705
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>            Mokena, IL 60448</p>	<p>Contact Person: Hoyt Ary          Phone: (708) 478-6190 Ext. 231           Contractor Registration #    Exp.</p>
--	---

Sincerely,

Daniel Starks