

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605 FOR OFFICE USE ONLY

Facility # 2-032652
Permit # 01666-2007UPG
Request Rec'd 10/11/2007
Amended Date
Approval Date 10/11/2007 DS
Permit Expires 4/11/2008

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Village of Villa Park 20 S. Ardmore Avenue Villa Park, IL 60181	Cornell Pumping Station 1260 S Cornell Ave Villa Park, Du Page Co., IL
Contact: Don Schleoner (630) 834-8505	Contact: Rick Cermak (630) 834-8505

(3) <u>UPGRADE OR REPAIR OF TANKS:</u>

- (a) Number and size of tanks being upgraded or repaired: (TK # 2) 600 gallons
- (b) Type of tanks:
- (c) Type of piping:
- (d) Product to be stored in each tank: (TK # 2) Heating Oil
- (e) Type of leak detection being used:

Tank: (TK # 2) - (Installing) Veeder Root TLS300c hydrostatic reservoir sensor, (TK # 2) - (Installing) Veeder Root TLS 300c automatic tank gauge

Piping: (TK # 2) - (Installing) Veeder Root TLS300c interstitial piping sump sensor

(f) Corrosion Protection being used:

Tank:

Piping:

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES:

(6)	PERSON.	, FIRM O	R COMPANY	PERFORMING	WORK:

Contact Person:

Janiel J. Starke

Phone: (708) 795-9052

Contractor Registration # Exp.

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 1/98)