



City of Chicago  
Department of Public Health  
333 South State Street, Room 200  
Chicago, IL 60604  
3127453162

**FOR OFFICE USE ONLY**

Facility # 2020715  
Permit # 00114-2021UPG  
Request Rec'd 01/29/2021  
Amended Date  
Approval Date 1/29/2021  
Permit Expires 7/29/2021

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Chicago Transit Authority 567 W. Lake St Chicago, IL 60661</p> <p>Contact: Symone Amos (312) 681-2747 Ext. 0</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>CTA North Park Bus Garage 3112 W. Foster Ave. Chicago, IL 60625</p> <p>Contact: Simone Amos (773) 539-2808</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 17, 18, 19, 20, 21) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 17, 18, 19, 20, 21) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 17, 18, 19, 20, 21) Spill Contain Device - Double Wall Spill Bucket*
- (h) Overfill prevention devices: (TK # 17, 18, 19, 20, 21) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

K-Plus Mechanical, Inc.  
10220 Bode Street Suite A  
Plainfield, IL 605851631

Contact Person: Gerald Ford  
Phone: (815) 230-3040  
Contractor Registration # IL002335 Exp. 2/9/2022

Sincerely,

  
Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist  
Division File