



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 4015246
Permit # 00137-2021UPG
Request Rec'd 02/02/2021
Amended Date
Approval Date 2/2/2021 DS
Permit Expires 8/3/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>LGP Realty Holdings, LP 600 Hamilton Street #500 Allentown, PA 18101</p> <p>Contact: Jeremy Holland (610) 625-8061</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Northern Retailers & Properties, LLC d/b/a Circle K #1338 314 South Line Road Tuscola, IL 61953</p> <p>Contact: Alyssa Shields (773) 386-4006</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 6) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 6) Piping - Partial (less than 20') Fiberglass Single Wall Piping Ameron , (TK # 6) Piping - Ball Valves, (TK # 6) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 6) - Gasoline - Regular*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

The supply piping from Regular tank T5 will be manifold to the piping of Regular tank T6 in the pump sump of tank T6 so that the piping from tank T5 will remian active from the manifold to the dispensers. Tank T5 is currently out-of-service and will be abandon in place soon.


NOTE: The partial SW piping being installed is less than 20' or 50% of the piping run and will only be to manifold in submersible sump and connect to existing SW piping for tank 6 outside of the sump.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: (708) 474-3344
Contractor Registration # IL1207 Exp. 2/14/2022

Sincerely,



Daniel S. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File