



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 3127453162

FOR OFFICE USE ONLY
 Facility # 2007484
 Permit # 00146-2021REM
 Request Rec'd 01/12/2021
 Amended Date
 Approval Date 2/3/2021
 Permit Expires 8/4/2021

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>City of Chicago/ Dept. of Aviation O'Hare International Airport 10510 West Zemke Rd Chicago, IL 60666</p> <p>Contact: Aaron Frame (773) 698-0534</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>O'Hare Fueling System Control Rm Bldg#790 NWC Hanger Area Chicago, IL 60666</p> <p>Contact: Mike Loveridge (773) 686-0534</p>
--	---

(3) REMOVAL OF PIPING:


- (a) Description/location of piping being removed:*
- (b) Which tank(s) are associated with the piping being removed: (TK # 19, 20, 21, 22, 23) - 50,000*
- (c) Reason of piping being removed:*
- (d) If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>RW Collins Company 7225 West 66th Street Chicago, IL 60638</p>	<p>Contact Person: Lisa Kruse Phone: (708) 458-6868 Contractor Registration # IL772 Exp. 2/9/2022</p>

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
 Division File