



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Extended

FOR OFFICE USE ONLY

Facility # 2016785
Permit # 01395-2020INS
Request Rec'd 10/01/2020
Amended Date
Approval Date 10/1/2020 DS
Permit Expires 10/5/2021

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Karim Oil Company, Inc. 5300 W. Touhy Ave. Skokie, IL 60077 Contact: Kamran Gaba (773) 909-3000	(2) <u>FACILITY</u> - name and address where tanks are located: Park Ridge Shell 2301 Touhy Avenue Park Ridge, IL 60068 Contact: Kamran Gaba (773) 909-3000
---	---

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 10) - 14,000, (TK # 11) - 8,000, (TK # 12) - 6,000*
- (b) Type of tank(s): (TK # 10, 11, 12) Tank - Fiberglass Double Wall Containment Solutions*
- (c) Type of piping: (TK # 10, 11, 12) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from tanks to dispensers as shown in site plan, (TK # 10, 11, 12) Piping - Single Wall STP/Tanktop Sump*
- (d) Product to be stored in each tank: (TK # 10) - Gasoline - Regular, (TK # 11) - Gasoline - Premium, (TK # 12) - Diesel Fuel*
- (e) Type of leak detection being used:*

Tank: (TK # 10, 11, 12) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350, (TK # 10, 11, 12) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring

Piping: (TK # 10, 11, 12) Leak Detect - Piping - Electronic Pressurized Line Leak Detection, (TK # 10, 11, 12) Leak Detect - Piping - Stand Alone Sensor Sump Sensor Non-Discriminating in all submersible and dispenser sumps

NOTE: Sensors MUST be wired for positive shut down

- (f) Corrosion Protection being used:*

Tank: (TK # 10, 11, 12) Corrosion Prot - Tank - Fiberglass Non-Corrosive

Piping: (TK # 10, 11, 12) Corrosion Prot - Piping - Fiberglass Non-Corrosive

- (g) Spill containment devices, piping and dispenser containment devices: (TK # 10, 11, 12) Spill Contain Device - Single Wall Spill Bucket*

- (h) Overfill prevention devices: (TK # 10, 11, 12) Overfill Prev Device - Overfill Drop Tube Valve*

- (4)** The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping

is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.


(6) SPECIAL CONTINGENCIES : NOTE: Contractor must submit a motor fuel dispensing permit ASAP

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Constellation Petroleum
27W441 Williams St.
Winfield, IL 601901518

Contact Person: Mohammed Hussain
Phone: (773) 507-0221
Contractor Registration # IL002438 Exp. 5/9/2021

Sincerely,

A handwritten signature in cursive script, reading "Daniel S. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File