



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 2177851020

FOR OFFICE USE ONLY
 Facility # 3034023
 Permit # 00219-2021REM
 Request Rec'd 02/24/2021
 Amended Date
 Approval Date 2/24/2021 DS
 Permit Expires 8/24/2021

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle (515) 965-6231</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Casey's #3892 1306 SE 3rd Street Aledo, IL 61231 Contact: Naginder Singh (515) 965-6238</p>
--	--


(3) REMOVAL OF PIPING:

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 1) - 12,000, (TK # 2, 3) - 10,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

(4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES : Removing product piping only to accommodate upgrade of facility. Vent piping to remain.

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>Total Petroleum Service Company 2421 Washington Road Washington, IL 61571</p>	<p>Contact Person: Greg McCoy Phone: (309) 694-8224 Contractor Registration # IL1079 Exp. 2/8/2022</p>

Sincerely,


Daniel Starks

cc: Storage Tank Safety Specialist
 Division File