



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2021803
Permit # 00266-2021REM
Request Rec'd 03/05/2021
Amended Date
Approval Date 3/8/2021 DS
Permit Expires 9/8/2021

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Kooshtard Property VI, LLC 1370 Ave of the Americas, 21st Floor New York, NY 10019 Contact: Elizabeth Patterson (812) 379-9227</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Bigfoot #176 590 South Washington Avenue Kankakee, IL 60901 Contact: Elizabeth Patterson (630) 800-6065</p>
---	--

(3) **REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 1, 5) - 8,000, (TK # 2) - 4,000, (TK # 3, 4) - 3,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2, 3, 4) - Gasoline, (TK # 5) - Gasoline - Premium*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 1, 5) - 12/17/2019, (TK # 2, 3, 4) - Unknown*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : Removing all tanks and piping from the site.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Steve Kryl
Phone: (708) 478-6190
Contractor Registration # IL002275 Exp. 6/10/2021

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File