



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 5020605
Permit # 00302-2021UPG
Request Rec'd 03/05/2021
Amended Date
Approval Date 3/15/2021 DS
Permit Expires 9/15/2021

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle (515) 965-6231</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Casey's General Store 401 North Cheney Taylorville, IL 62568 Contact: Cindy Nation (515) 965-6238</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 7) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 7) Piping - Flexible Double Wall OPW Pisces, (TK # 7) Piping - Positive Shutoff Valves, (TK # 7) Piping - Shear Valves*
- (d) Product to be stored in each tank: (TK # 7) - Gasoline - Mid-grade*
- (e) Type of leak detection being used:*
 - Tank: (TK # 7) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD, (TK # 7) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring*
 - Piping: (TK # 7) Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices: (TK # 7) Overfill Prev Device - Overfill Drop Tube Valve*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Product Change in tank #7 from Midgrade to E-85. Installing (4) New Gilbarco 700S Encore NF8 Multi Product Blending Dispensers, EBW E-85 Compatible Sheer Valves 662502902 & related SS fittings. Installing Morrison SS Ball Valve & related SS fittings in the tank sump #7. Installing Veeder Root Probe & Float Kit 846391-407 Veeder Root non-discriminating Sump Sensors w/ positive shut down. 794380-323 Installing EBW Overfill Drop tube 708592922 Installing with Gasolia E-Seal

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Seneca Companies, Inc.

Contact Person: Glen Davis

4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2022

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File